



Lead and Copper Rule Revision and Lead and Copper Rule Improvement

Thomas Shiparski, NMED Lead and Copper Rule administrator

October 16th, 2025



2

October 16, 2024

- **What should already be submitted**
- **What you should be working on now**
- **Future deadlines**

November 01, 2027

December 31, 2033

November 2037



3

October 16, 2024

- **What should already be submitted**
- What you should be working on now
- Future deadlines

November 01, 2027

December 31, 2033

November 2037



What should already be submitted

- ☐ Lead Service Line Inventory
- ☐ List of schools and daycares
- ☐ Tiered sample locations list



What should already be submitted

- ☐ Lead Service Line Inventory
- ☐ List of schools and daycares
- ☐ Tiered sample locations list



What should already be submitted

- ❑ Lead Service Line Inventory
 - Create a SWIFT account



[Log in](#)

Register

Create a new account.

First Name

Last Name

Organization

Agency

Application

Water Systems

Phone Number

Email

User Name (Used to Log In)

Password



What should already be submitted

□ Lead Service Line Inventory

■ Create a SWIFT account

Link to register

<https://nm.gecsws.com/Account/Register?ag=NMED&app=SSBMT>

- Pay attention to password instructions (can only have one special character)

A valid password must contain:

- 14 characters minimum
- at least one lower case letter
- at least one upper case letter
- at least one number
- one special character (&, ^, ', @, -, _ , !, |, /, \, (,), {, }, [,], \$)

- You will need to create a 4 digit PIN. Your PIN is retrievable from your account profile once logged in.
- Once you register, you should receive an email from contact@1gec.com to complete this process. *You must complete the process within 2 hours of receiving the follow up email.* The email can always be resent.



What should already be submitted

- ❑ Lead Service Line Inventory
 - ▣ Once logged in


A screenshot of the SWIFT SUBMITTALS application interface. The top navigation bar is blue with the "SWIFT SUBMITTALS" logo on the left, "HOME" in the center, and a welcome message "Welcome Thomas" and "Powered by GE" on the right. A left sidebar contains navigation links: "Home", "SUBMIT", "Files & Reports", "Lead Service Lines", "Update Service Line(s)", and "Submit to State". The main content area shows a "Water System" dropdown menu with "All my systems" selected, indicated by a yellow arrow. Below this is a "Service Line Identification Percentage" section with a progress bar at 39%. To the right is a "Summary of Service Line Categories" section with a pie chart and a legend: Lead - 0.01% (orange), GRR - 0.06% (blue), Non-Lead - 39.15% (green), and Unknown - 60.79% (grey).

Select your system



What should already be submitted

- ❑ Lead Service Line Inventory
 - ▣ Once logged in



Select your system

Select Update Service Line(s)



What should already be submitted

- ❑ Lead Service Line Inventory
 - ▣ Once logged in

A screenshot of the SWIFT SUBMITTALS web application. The header bar is blue with the "SWIFT SUBMITTALS" logo on the left, the title "UPDATE LEAD SERVICE LINE(S)" in the center, and a user greeting "Welcome Thomas Powered by GEC" on the right. A left-hand navigation menu contains links for "Home", "SUBMIT", "Files & Reports", "Lead Service Lines", "Update Service Line(s)", and "Submit to State". The main content area is titled "UPDATE LEAD SERVICE LINE INVENTORY" and includes instructions: "Update existing service line data or add a new service line to the LSLI database. Then submit the updates to the State." Below this is a "Water System" dropdown menu, which is currently empty and has a red border with the error message "Water System is required" below it. To the right of the dropdown are two buttons: "+ Add New Service Line" and "Batch Uploads". A large yellow arrow points from the dropdown menu to the "Batch Uploads" button.

Select your system

Select Update Service Line(s)

Select Batch Uploads



What should already be submitted

- Lead Service Line Inventory
 - ▣ Once logged in

A screenshot of the SWIFT SUBMITTALS BATCH UPLOADS interface. The page has a blue header with the SWIFT SUBMITTALS logo on the left, the text "BATCH UPLOADS" in the center, and a welcome message "Welcome Thomas Powered by GEC" on the right. A left sidebar contains navigation links: Home, SUBMIT, Files & Reports, Lead Service Lines, Update Service Line(s), and Submit to State. The main content area is titled "Lead Service Line Inventory Template Uploads & Imports" and contains instructions: "Upload data for multiple service lines at once using the Excel template or APIs. After uploaded data is validated, review for errors and make changes before importing into your Lead Service Line Inventory (LSLI). Use [Submit to State](#) to submit the LSLI updates to the state on the frequency required by the state." Below the instructions is a dropdown menu labeled "Water System" with a red border and a red dot above it. A red error message "Water System is required" is displayed below the dropdown. A yellow arrow points to the "Download Excel Template" button. The "Upload From Excel File" button is also visible on the right.

Select your system

Select Update Service Line(s)

Select Batch Uploads

Select Download Excel Template





What should already be submitted

□ Lead Service Line Inventory

- Itemized, detailed inventory of each of your service lines with at least 5 columns filled out
 1. Column A – Unique Service Line ID
 2. Column B - street address including city , State and zip
 3. Column F – material of system owned portion
 4. Column O – Material of Customer owned portion
 5. Column W – over all classification



A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U	V	W	
1	Location Information					System-Owned Portion									Customer-Owned Portion							Entire Service Line	
	Unique Service Line ID*	Street Address*	Other Location Identifier	Sensitive Population? (Yes/No)	Disadvantaged Neighborhood? (Yes/No)	System-Owned Portion Service Line Material Classification*	If Non-Lead, Was Material Ever Previously Lead?	Service Line Installation Date (System Portion)	Service Line Size (inches) (System Portion)	Basis of Material Classification (System Portion)	Was the Service Line Material Field Verified? (System Portion)	Describe the Field Verification Method (System Portion)	Enter the Date of Field Verification (System Portion)	Notes (System Portion)	Customer-Owned Portion Service Line Material Classification*	Service Line Installation Date (Customer Portion)	Service Line Size (inches) (Customer Portion)	Basis of Material Classification (Customer Portion)	Was the Service Line Material Field Verified? (Customer Portion)	Describe the Field Verification Method (Customer Portion)	Enter the Date of Field Verification (Customer Portion)	Notes (Customer Portion)	Entire Service Line Material Classification (by Water System)
2																							
3	1002	20 Main St. Cityville, NM 8755				Non-Lead - Plastic									Non-Lead - Plastic							Non-Lead	
4	1003	26 Main St. Cityville, NM 8755				Non-Lead - Plastic									Non-Lead - Plastic							Non-Lead	
5	1004	278 Sunrise Blvd.Cityville, NM 8755				Non-Lead - Plastic									Non-Lead - Plastic							Non-Lead	
6	1005	13 Birch Tree Rd. Cityville, NM 8755				Non-Lead - Plastic									Non-Lead - Plastic							Non-Lead	
7	1006	1645 Washington Ave. Cityville, NM 8755				Non-Lead - Plastic									Non-Lead - Plastic							Non-Lead	
8	1007	213 Oak Dr. Cityville, NM 8755				Non-Lead - Plastic									Non-Lead - Plastic							Non-Lead	
9	1008	9811 Smith St. Cityville, NM 8755				Non-Lead - Plastic									Non-Lead - Plastic							Non-Lead	
10	1009	72 Plymouth Cir. Cityville, NM 8755				Non-Lead - Plastic									Non-Lead - Plastic							Non-Lead	
11	1010	717 Cactus Ln. Cityville, NM 8755				Non-Lead - Plastic									Non-Lead - Plastic							Non-Lead	
12	1011	545 Carter Rd. Cityville, NM 8755				Non-Lead - Plastic									Non-Lead - Plastic							Non-Lead	
13	1012	440 Sully Ave. Cityville, NM 8755				Non-Lead - Plastic									Non-Lead - Plastic							Non-Lead	
14	1013	301 First St. Cityville, NM 8755				Non-Lead - Plastic									Non-Lead - Plastic							Non-Lead	
15	1014	214 Birds nest lane Cityville, NM 8755				Non-Lead - Plastic									Non-Lead - Plastic							Non-Lead	



What should already be submitted

- Lead Service Line Inventory
 - ▣ Once logged in

A screenshot of the SWIFT SUBMITTALS web application. The header bar is blue with the "SWIFT SUBMITTALS" logo on the left, the title "UPDATE LEAD SERVICE LINE(S)" in the center, and a user greeting "Welcome Thomas Powered by GEC" on the right. A left-hand navigation menu contains links for "Home", "SUBMIT", "Files & Reports", "Lead Service Lines", "Update Service Line(s)", and "Submit to State". The main content area is titled "UPDATE LEAD SERVICE LINE INVENTORY" and includes instructions: "Update existing service line data or add a new service line to the LSLI database. Then submit the updates to the State." Below this is a "Water System" dropdown menu, which is currently empty and has a red border with the error message "Water System is required" below it. To the right of the dropdown are two buttons: "+ Add New Service Line" and "Batch Uploads". A large yellow arrow points from the dropdown menu to the "Batch Uploads" button.

Select your system

Select Update Service Line(s)

Select Batch Uploads



What should already be submitted

Home

SUBMIT

Files & Reports

Lead Service Lines

Update Service Line(s)

Submit to State

SUBMITTALS

History

BATCH UPLOADS

Welcome Brandi
Powered by GEC

Lead Service Line Inventory Template Uploads & Imports

Upload data for multiple service lines at once using the Excel template or APIs. After uploaded data is validated, review for errors and make changes before importing into your Lead Service Line Inventory (LSLI). Use [Submit to State](#) to submit the LSLI updates to the state on the frequency required by the state.

Water System

NM3576207 -DOVE CANYON LLC

Download Excel Template

Upload From Excel File

File Uploads

User	Date	# Of Records	Upload Status	Actions
No records available.				

- Select your system
- Select Update Service Line(s)
- Select Batch Uploads
- Select Upload From Excel File

Errors

17

All Errors Must Be Corrected

Uploaded By:
Brandi Littleton

Upload Date:
04/13/2025

Total File # Records:
10

Total # Records:
10

of Records with Errors:
2

of Records with Valid Changes:
8

of Records with No Changes:
0

Status:
Ready for review

Service Line ID	Service Line Address	Status	Actions
2	3815 S. Main Street, Mesilla Park, NM 88047	!! Invalid	Edit Delete
3	3815 S. Main Street, Mesilla Park, NM 88047	!! Invalid	Delete
1	3815 S. Main Street, Mesilla Park, NM 88047	Valid	View Changes Delete
7	3815 S. Main Street, Mesilla Park, NM 88047	Valid	View Changes Delete
6	3815 S. Main Street, Mesilla Park, NM 88047	Valid	Edit View Changes Delete
8	3815 S. Main Street, Mesilla Park, NM 88047	Valid	Edit View Changes Delete
10	3815 S. Main Street, Mesilla Park, NM 88047	Valid	Edit View Changes Delete
5	3815 S. Main Street, Mesilla Park, NM 88047	Valid	Edit View Changes Delete
	3815 S. Main Street, Mesilla Park,		

Import Information

18

Once errors are corrected, inventory must be Imported and Submitted to State

Uploaded By:
Brandi Littleton

Upload Date:
04/13/2025

Total File # Records:
10

Total # Records:
10

of Records with Errors:
0

of Records with Valid Changes:
10

of Records with No Changes:
0

Status:
Ready for review

Service Line ID	Service Line Address	Status	Actions
1	3815 S. Main Street, Mesilla Park, NM 88047	Valid	Edit View Changes Delete
7	3815 S. Main Street, Mesilla Park, NM 88047	Valid	Edit View Changes Delete
6	3815 S. Main Street, Mesilla Park, NM 88047	Valid	Edit View Changes Delete
8	3815 S. Main Street, Mesilla Park, NM 88047	Valid	Edit View Changes Delete
10	3815 S. Main Street, Mesilla Park, NM 88047	Valid	Edit View Changes Delete
5	3815 S. Main Street, Mesilla Park, NM 88047	Valid	Edit View Changes Delete
4	3815 S. Main Street, Mesilla Park, NM 88047	Valid	Edit View Changes Delete
9	3815 S. Main Street, Mesilla Park, NM 88047	Valid	Edit View Changes Delete

1 25 items per page

[Return to Uploads Page](#)

[Discard Upload](#)

[Import Information](#)



Confirm Action

Uploaded By: Brandi Littleton

Upload Date: 04/13/2025

Total File # Records: 10

of Records with Errors: 0

of Records with Valid Changes: 10

of Records with No Changes: 0

Service Line ID	Service Line Address	Status	Actions
1			Edit View Cha
7			Edit View Cha
6			Edit View Cha
8			Edit View Cha
10	3815 S. Main Street, Mesilla Park, NM 88047	Valid	Edit View Cha
5	3815 S. Main Street, Mesilla Park, NM 88047	Valid	Edit View Cha
4	3815 S. Main Street, Mesilla Park, NM 88047	Valid	Edit View Cha
9	3815 S. Main Street, Mesilla Park, NM 88047	Valid	Edit View Cha

Confirm action

Do you want to continue with the Import of your records?

No

Yes



What should already be submitted

Summary [X]

The information for 10 service lines has been added to your lead service line inventory.

Records are currently being processed. You can view the status on the Import from Template page.

Previous LSLI numbers		Current LSLI numbers	
Lead	0	Lead	0
GRR	0	GRR	0
Unknown	0	Unknown	10
Non-Lead	0	Non-Lead	0

Ok Submit to State

Total # Records: 10

Status: Ready for review

3815 S. Main Street, Mesilla Park, NM 88047 Valid

3815 S. Main Street, Mesilla Park, NM 88047 Valid

3815 S. Main Street, Mesilla Park, NM 88047 Valid

3815 S. Main Street, Mesilla Park, NM 88047 Valid

Submit to State

21

All fields with an asterisk (*) must be filled out

Water System

NM3576207 - DOVE CANYON LLC

WATER SYSTEM INFORMATION FOR LEAD & COPPER RULE

NM3576207 - DOVE CANYON LLC

Federal System Type
C

Population
393

Service Connections
150

Sampling Frequency
5 RT - EVERY 3 YEARS

Collection Period
6/1 - 9/30

Initial Monitoring Period Begin Date
01/01/2011

Primary Service Area Type
MOBILE HOME PARK

Do multi-family residences comprise at least 20% of the structures you serve?

Yes



System Contact Name *

System Contact Title *

System Contact Phone *

System Contact Email *

LSLI Preparer Name *



LSLI Preparer Title *



LSLI Preparer Phone *



LSLI Preparer Email



Submit to State

22

SUMMARY

Updated Service
Lines:

0

Total Service Lines
in Inventory:

0

Service Line Lead Category	Old Value	New Value
Lead	0	0
GRR	0	0
Unknown	0	0
Non-Lead	0	0



Submit to State



Confirm Inventory

- To complete the process, you will need to certify the inventory by checking the certify box, entering your PIN number and selecting Certify & Submit

A screenshot of a web application showing a modal dialog box titled "Confirm Submit to State". The dialog box has a dark blue header with a close button (X) in the top right corner. Below the header, there is a checkbox that is checked, with the text "I certify that, to the best of my knowledge, the information submitted is correct as of the date submitted: 04/13/25." A yellow arrow points to this checkbox. Below the checkbox, the text "Please provide your PIN" is displayed. Underneath this text is a light blue input field containing four dots. A yellow arrow points to the "Certify & Submit" button, which is a blue button with white text located at the bottom right of the dialog box. The background of the screenshot shows a table with columns for address, status, and date, with rows partially visible.



24

Inventory update

Until the system is marked as “Lead Free” by the state, an updated inventory must be submitted by January 30th annually.

If you make small changes to your systems inventory through SWIFT as line materials are discovered or replaced, an updated inventory is not required.

A single Public Notice is required annually that describes the changes made to the inventory. This can be added to your CCR.



What should already be submitted

- ☐ Lead Service Line Inventory
- ☐ List of schools and daycares
- ☐ Tiered sample locations list



What should already be submitted

- List of schools and daycares or statement declaring that there are no schools/daycares

Water System name:

PWSS:

St. Petersburg High School	1234 Test St., City, State, Zip Code
Plant High School	4321 Test St., City, State, Zip Code
Sickles Elementary	16 Capital St., City, State, Zip Code
Central Elementary	1 Water Avenue, City, State, Zip Code
Unified Mid High	67 Children's Place, City, State, Zip Code
ABC Daycare	30 Price Street, City, State, Zip Code
Early Opportunities Preschool	3 System Ave., City, State, Zip Code
Fulton Elementary	921 System Ave., City, State, Zip Code
Davies early learning	3310 Test St., City, State, Zip Code
Potterville Early development	4591 Test St., City, State, Zip Code
John Muir Elementary	16200 Capital St., City, State, Zip Code
Perkins Elementary	10697 Water Avenue, City, State, Zip Code
Grant Mid High	6754 Children's Place, City, State, Zip Code
Bethane Daycare	3045 Price Street, City, State, Zip Code
Long fellow Preschool	13 System Ave., City, State, Zip Code
Logan Memorial Elementary	1483 System Ave., City, State, Zip Code

September 12th, 2024

Diana Ischel Aranda
Lead and Copper Rule (LCR) Administrator
NM Environment Department
Drinking Water Bureau
123 Tigas Avenue, NE Ste 1000
Albuquerque NM 87107

Re: New Mexico Water Service, Monterey Water System (NM1509012) – List of Schools and Childcare Facilities

Dear Ms. Aranda,

I am writing in response to your request for a list of schools and childcare facilities served by New Mexico Water Service (NMWS). Monterey Water system (NM1509012). NMWS owns and operates the Monterey Water system and is responsible for all lead and copper sampling as outlined in the Lead and Copper Rule (LCR), and subsequent Lead and Copper Rule Revisions (LCRR) and Improvements (LCRI) regulations. We have carefully reviewed our records and 2 state databases: <https://childcare.ececd.nm.gov> and <https://search.newmexikids.org>, to ensure all information provided is accurate and up to date and determined that there are no schools or childcare facilities within the Monterey Water service area.

If you require further details or have any additional questions, please do not hesitate to contact Angel Villa at (505) 525-9580 or at avilla@newmexicowater.com.

Sincerely,

Cynthia Apodaca
General Manager



What should already be submitted

- List of Schools & Daycares
 - ▣ Once logged in

A screenshot of the SWIFT SUBMITTALS web application interface. The top navigation bar is blue with the "SWIFT SUBMITTALS" logo on the left, "HOME" in the center, and a welcome message "Welcome Thomas" and "Powered by GE" on the right. A left sidebar contains a "SUBMIT" section with links: "Home", "Files & Reports", "Lead Service Lines", "Update Service Line(s)", and "Submit to State". A yellow arrow points to the "Files & Reports" link. The main content area shows a "Water System" dropdown menu with "All my systems" selected. Below this is a "Service Line Identification Percentage" section with a progress bar at 39%. To the right is a "Summary of Service Line Categories" section with a pie chart and a legend.

Category	Percentage
Lead	0.01%
GRR	0.06%
Non-Lead	39.15%
Unknown	60.79%

Select your system

Select Files and Reports



What should already be submitted

- List of Schools & Daycares
 - ▣ Once logged in

A screenshot of the SWIFT SUBMITTALS web application. The top navigation bar is blue with the "SWIFT SUBMITTALS" logo on the left, the title "SUBMIT FILE/REPORT" in the center, and a user greeting "Welcome Thomas" with a "Powered by GEC" logo on the right. A left sidebar contains navigation links: "Home", "SUBMIT" (with a dropdown arrow), "Files & Reports", "Lead Service Lines", "Update Service Line(s)", "Submit to State", and "SUBMITTALS" (with a dropdown arrow). The main content area is titled "File & Report Types" and contains two dropdown menus. The first dropdown, labeled "Water System", is empty and has a red error message "Water System is required" below it. The second dropdown, labeled "File/Report Type", is open and shows a list of options: "Select a File/Report Type", "LCRR Tap Sampling Plan", "Lead Consumer Notice and Certification", "Lead Public Education and Certification", "Lead Service Line Replacement Plan", and "List of Schools & Childcare Centers". A large yellow arrow points to the "List of Schools & Childcare Centers" option. Below the dropdowns is a "Select File" section with a "Select file..." button and a "Drop files here to select" area. At the bottom right are "Cancel" and "Upload File" buttons.

Select your system

Select Files and Reports

Select List of Schools & Childcare Centers from the dropdown menu



What should already be submitted

- List of Schools & Daycares
 - ▣ Once logged in

A screenshot of the SWIFT SUBMITTALS web application. The top navigation bar is blue with the "SWIFT SUBMITTALS" logo on the left, the title "SUBMIT FILE/REPORT" in the center, and a user greeting "Welcome Thomas" with a "Powered by GEO" logo on the right. A left sidebar contains navigation links: "Home", "SUBMIT" (with a dropdown arrow), "Files & Reports", "Lead Service Lines", "Update Service Line(s)", "Submit to State", and "SUBMITTALS" (with a dropdown arrow). The main content area is titled "File & Report Types" and contains two dropdown menus. The first, labeled "Water System", has a red border and a red error message "Water System is required" below it. The second, labeled "File/Report Type", has the text "List of Schools & Childcare Centers" selected. Below these is a "Select File" section with a "Select file..." button and a "Drop files here to select" area. At the bottom right are "Cancel" and "Upload File" buttons. A large yellow arrow points to the "Upload File" button.

Select your system

Select Files and Reports

Select List of Schools & Childcare Centers from the dropdown menu

Select Upload File



What should already be submitted

- ☐ Lead Service Line Inventory
- ☐ List of schools and daycares
- ☐ Tiered sample locations list



What should already be submitted

31

Tiered Sample Location List

LCR TIER STRUCTURE

Tier 1	Sampling sites are single-family structures with premise plumbing made of lead and/or served by a lead service line
Tier 2	Sampling sites are buildings, including multiple-family residences, with premise plumbing made of lead and/or served by a lead service line.
Tier 3	Sampling sites are sites that are served by a lead connector. Tier 3 sites are also sites served by a galvanized service line or containing galvanized premise plumbing identified as ever having been downstream of a lead service line. Tier 3 for community water systems only includes single-family structures.
Tier 4	Sampling sites are sites that contain copper premise plumbing with lead solder installed before the effective date of the Statnhe's applicable lead ban. Tier 4 for community water systems only includes single-family structures.
Tier 5	Sampling sites are sites that are representative of sites throughout the distribution system. A representative site is a site in which the plumbing materials used at that site would be commonly found at other sites served by the water system.

Site Name	Site name and address	Type of Tier	Type of service line plumbing material	Date of construction/notes
LCR1T1	20 Main St.	1	Lead	1935
LCR2T3	26 Main St.	3	Galvanized	1945
LCR3T3	278 Sunrise Blvd.	3	Galvanized	1985
LCR4T5	13 Birch Tree Rd.	5	Unknown	1977
LCR5T5	1645 Washington Ave.	5	Unknown	1980
LCR 6T4	213 Oak Dr.	4	Copper	1986
Standard monitoring				
LCR 7T5	9811 Smith St.	5	Unknown	1983
Standard monitoring				
LCR 8T5	72 Plymouth Cir.	5	Plastic	1956
Standard monitoring				
LCR 9T5	717 Cactus Ln.	5	Plastic	1979
Standard monitoring				
LCR 10T5	545 Carter Rd.	5	Unknown	1997
Standard monitoring				
LCR11T5 Alternative	440 Sully Ave.	5	Unknown	1990
LCR12T5 Alternative	301 First St.	5	Unknown	2001
LCR13T5 Alternative	214 Birds nest lane	5	Plastic	2014

Site Name	Site name and address	Type of Tier	Type of service line plumbing material	Date of construction/notes
LCR1T1	20 Main St.	1	Lead	1935
LCR2T3	26 Main St.	3	Galvanized	1945
LCR3T3	278 Sunrise Blvd.	3	Galvanized	1985
LCR4T5	13 Birch Tree Rd.	5	Unknown	1977
LCR5T5	1645 Washington Ave.	5	Unknown	1980
LCR 6T4	213 Oak Dr.	4	Copper	1986
Standard monitoring				
LCR 7T5	9811 Smith St.	5	Unknown	1983
Standard monitoring				
LCR 8T5	72 Plymouth Cir.	5	Plastic	1956
Standard monitoring				
LCR 9T5	717 Cactus Ln.	5	Plastic	1979
Standard monitoring				
LCR 10T5	545 Carter Rd.	5	Unknown	1997
Standard monitoring				
LCR11T5 Alternative	440 Sully Ave.	5	Unknown	1990
LCR12T5 Alternative	301 First St.	5	Unknown	2001
LCR13T5 Alternative	214 Birds nest lane	5	Plastic	2014

Site Name	Site name and address	Type of Tier	Type of service line plumbing material	Date of construction/notes
LCR1T1	20 Main St.	1	Lead	1935
LCR2T3	26 Main St.	3	Galvanized	1945
LCR3T3	278 Sunrise Blvd.	3	Galvanized	1985
LCR4T5	13 Birch Tree Rd.	5	Unknown	1977
LCR5T5	1645 Washington Ave.	5	Unknown	1980
LCR 6T4	213 Oak Dr.	4	Copper	1986
Standard monitoring				
LCR 7T5	9811 Smith St.	5	Unknown	1983
Standard monitoring				
LCR 8T5	72 Plymouth Cir.	5	Plastic	1956
Standard monitoring				
LCR 9T5	717 Cactus Ln.	5	Plastic	1979
Standard monitoring				
LCR 10T5	545 Carter Rd.	5	Unknown	1997
Standard monitoring				
LCR11T5 Alternative	440 Sully Ave.	5	Unknown	1990
LCR12T5 Alternative	301 First St.	5	Unknown	2001
LCR13T5 Alternative	214 Birds nest lane	5	Plastic	2014

Site Name	Site name and address	Type of Tier	Type of service line plumbing material	Date of construction/notes
LCR1T1	20 Main St.	1	Lead	1935
LCR2T3	26 Main St.	3	Galvanized	1945
LCR3T3	278 Sunrise Blvd.	3	Galvanized	1985
LCR4T5	13 Birch Tree Rd.	5	Unknown	1977
LCR5T5	1645 Washington Ave.	5	Unknown	1980
LCR 6T4	213 Oak Dr.	4	Copper	1986
Standard monitoring				
LCR 7T5	9811 Smith St.	5	Unknown	1983
Standard monitoring				
LCR 8T5	72 Plymouth Cir.	5	Plastic	1956
Standard monitoring				
LCR 9T5	717 Cactus Ln.	5	Plastic	1979
Standard monitoring				
LCR 10T5	545 Carter Rd.	5	Unknown	1997
Standard monitoring				
LCR11T5 Alternative	440 Sully Ave.	5	Unknown	1990
LCR12T5 Alternative	301 First St.	5	Unknown	2001
LCR13T5 Alternative	214 Birds nest lane	5	Plastic	2014



What should already be submitted

36

Tiered sample location list submission

Your tiered sample location list can be submitted to SWIFT through **“Files & Reports”**, the same way you would add your schools and daycare list

or

It can just be added to your DSSP and a new copy of your DSSP emailed to lcr.manager@env.nm.gov



What should you be working on now?

37

October 16, 2024 – inventory submitted to the state due

November 18, 2024 – public notice of what materials were found in the inventory due

January 30, 2026 – Public notice of what material update in inventory since its original submittal due

January 30, 2027 – Public notice of what material update in inventory since its original submittal due

November 01, 2027 – Validation pool and replacement plan due.

December 01, 2027 – Public Notice of validation pool and replacement plant due

January 30, 2029 – Public notice of what material update in inventory since its original submittal due



38

What should you be working on now?

Identifying “unknown” Service Lines

All “Unknown” service lines need to be identified by November 01, 2027 or included on the systems replacement plan due November 01, 2027.



What if I have 2000 “Unknown” service lines?!?!

39

Options

Predictive/Probabilistic modeling

Documentation as you go out to service/ read meters



What is due November 01, 2027

- ☐ Replacement Plan
- ☐ Validation Pool



What is due November 01, 2027

- ☐ Replacement Plan
- ☐ Validation Pool



What is due November 01, 2027

□ Replacement Plan

Your replacement plan needs to include all service lines that have been identified as containing lead, Galvanized requiring replacement or **Unknown**.

All “Unknown” service lines need to be identified by November 01, 2027 or included on the systems replacement plan due November 01, 2027.



What is due November 01, 2027

□ Replacement Plan



NEW MEXICO DRINKING WATER SYSTEM LEAD SERVICE LINE REPLACEMENT PLAN

PWS Name Click or tap here to enter text.	PWS ID # Click or tap here to enter text.
All Community and Non-Transient Non-Community Public Water Systems with one or more lead, galvanized requiring replacement, or lead status unknown service lines in their inventory must submit a Lead Service Line Replacement Plan (LSLRP) to the NMED Drinking Water Bureau (DWB) as described in 40 CFR 141.84(b). This plan helps water systems identify, prioritize, and commence replacement of Lead Service Lines (LSLs), including public and private portions. The LSLRP enables systems to quickly commence replacement upon an action or trigger level exceedance in accordance with 40 CFR 141.84. It also ensures readiness to address customer-initiated requests for lead service line replacement. While other formats are acceptable, DWB recommends using the provided template for creating your system's plan. LSLRPs must be submitted to your DWB by October 16, 2024, and updated as necessary thereafter. LSLRPs can be submitted along with your Service Line Inventory at this link: https://nmed.commentinput.com/?id=HmbasedKC4 . Please use the following file naming convention: <u>"RP_Year-month-day_ WaterSystem#_ Water System Name"</u>	



What is due November 01, 2027

□ Replacement Plan

- **Procedures to conduct Full Lead Service Line Replacement**
 - Who will conduct the replacement? What materials will be used? The Water systems authority to access private property for service line replacement. How will the system handle customer-initiated replacements or coordinate replacements with planned infrastructure work.
- **Procedures for how to inform customers of service line replacement**
 - *describe the distribution method(s) the water system will use to notify customers before and after service line replacement. These can include methods already used to communicate with customers.*



What is due November 01, 2027

□ Replacement Plan

- **Procedures for Customers to Flush Particulate Lead**
 - *The steps the system will provide to customers to flush service lines and premise plumbing of particulate lead following a lead service line replacement or disturbance, and describe the method(s) the system will use to notify customers of flushing procedures*
- **Funding Strategy for Conducting Lead Service Line Replacements**
 - *Describe how the water system will fund lead service line replacements in the service area and how the system will accommodate customers that are unable to pay for or replace the portion of service line they own. For example, include a cost estimate for utility-owned service line replacements as well as cost for replacement or reimbursement of the customer-owner service lines, and discuss whether rate adjustments are necessary to fund customer-owned service line replacements*



What is due November 01, 2027

□ Replacement Plan

- **Prioritization Strategy for Lead Service Line Replacement**
 - *Describe how the water system will prioritize lead service line replacement in the service area based on factors including, but not limited to, targeting of known lead service lines, lead service line replacement for disadvantaged consumers, and targeting populations most sensitive to lead.*
- **Estimated timeline**



What is due November 01, 2027

- ☐ Replacement Plan
- ☐ Validation Pool



What is due November 01, 2027

☐ **Validation Pool**

The validation pool consists of all service lines categorized as “non-lead,”

Service lines with records of installation after June 19, 1988 should be excluded.



What is due November 01, 2027

Validation Pool

	A				B				C	D	E	F				G	H	I	J	K	L	M	N	O				P	Q	R	S	T	U	V	W
1	Location Information								System-Owned Portion														Customer-Owned Portion										Entire Service Line		
	Unique Service Line ID*	Street Address*			Other Location Identifier	Sensitive Population? (Yes/No)	Disadvantaged Neighborhood? (Yes/No)	System-Owned Portion Service Line Material Classification*	If Non-Lead, Was Material Ever Previously Lead?	Service Line Installation Date (System Portion)	Service Line Size (inches) (System Portion)	Basis of Material Classification (System Portion)	Was the Service Line Material Field Verified? (System Portion)	Describe the Field Verification Method (System Portion)	Enter the Date of Field Verification (System Portion)	Notes (System Portion)	Customer-Owned Portion Service Line Material Classification*	Service Line Installation Date (Customer Portion)	Service Line Size (inches) (Customer Portion)	Basis of Material Classification (Customer Portion)	Was the Service Line Material Field Verified? (Customer Portion)	Describe the Field Verification Method (Customer Portion)	Enter the Date of Field Verification (Customer Portion)	Notes (Customer Portion)	Entire Service Line Material Classification (by Water System)										
2																																			
3	1001	123 example st. cityville NM, 87555						Non-Lead - Plastic		2001							Non-Lead - Plastic	2202																	Non-Lead
4	1002	124 example st. cityville NM, 87555						Galvanized		1989							Galvanized	1990																	Non-Lead
5	1003	125 example st. cityville NM, 87555						Non-Lead - Plastic		1994							Non-Lead - Plastic	1995																	Non-Lead
6	1004	126 example st. cityville NM, 87555						Non-Lead - Plastic		2002							Non-Lead - Plastic	2002																	Non-Lead
7	1005	127 example st. cityville NM, 87555						Non-Lead - Copper		1974							Non-Lead - Copper	1975																	Non-Lead
8	1006	128 example st. cityville NM, 87555						Non-Lead - Copper		1981							Non-Lead - Copper	1982																	Non-Lead
9	1007	129 example st. cityville NM, 87555						Galvanized		1988							Galvanized	1989																	Non-Lead
10	1008	130 example st. cityville NM, 87555						Non-Lead - Plastic		1994							Non-Lead - Plastic	1995																	Non-Lead
11	1009	131 example st. cityville NM, 87555						Non-Lead - Plastic		1995							Non-Lead - Plastic	1996																	Non-Lead
12	1010	132 example st. cityville NM, 87555						Non-Lead - Plastic		1995							Non-Lead - Plastic	1996																	Non-Lead
13	1011	133 example st. cityville NM, 87555						Non-Lead - Copper		1980							Non-Lead - Copper	1981																	Non-Lead
14	1012	134 example st. cityville NM, 87555						Non-Lead - Plastic		1997							Non-Lead - Plastic	1981																	Non-Lead
15	1013	135 example st. cityville NM, 87555						Non-Lead - Plastic		2002							Non-Lead - Plastic	1998																	Non-Lead
16	1014	136 example st. cityville NM, 87555						Galvanized		1985							Galvanized	1986																	Non-Lead
17	1015	137 example st. cityville NM, 87555						Non-Lead - Plastic		1991							Non-Lead - Plastic	1992																	Non-Lead
18	1016	138 example st. cityville NM, 87555						Non-Lead - Plastic		1997							Non-Lead - Plastic	1998																	Non-Lead
19	1017	139 example st. cityville NM, 87555						Galvanized		1990							Galvanized	1998																	Non-Lead
20	1018	140 example st. cityville NM, 87555						Galvanized		1977							Galvanized	1978																	Non-Lead
21	1019	141 example st. cityville NM, 87555						Non-Lead - Plastic		2000							Non-Lead - Plastic	2000																	Non-Lead
22	1020	142 example st. cityville NM, 87555						Non-Lead - Plastic		2001							Non-Lead - Plastic	2002																	Non-Lead
23	1021	143 example st. cityville NM, 87555						Non-Lead - Copper		2000							Non-Lead - Copper	2001																	Non-Lead
24	1022	144 example st. cityville NM, 87555						Non-Lead - Copper		1985							Non-Lead - Copper	1986																	Non-Lead
25	1023	145 example st. cityville NM, 87555						Non-Lead - Plastic		1986							Non-Lead - Plastic	1987																	Non-Lead
26	1024	146 example st. cityville NM, 87555						Non-Lead - Copper		1981							Non-Lead - Copper	1982																	Non-Lead
27	1025	147 example st. cityville NM, 87555						Lead		1960							Lead	1960																	Lead

Initial inventory



What is due November 01, 2027

	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U	V	W
1	Location Information					System-Owned Portion									Customer-Owned Portion							Entire Service Line	
	Unique Service Line ID*	Street Address*	Other Location Identifier	Sensitive Population? (Yes/No)	Disadvantaged Neighborhood? (Yes/No)	System-Owned Portion Service Line Material Classification*	If Non-Lead, Was Material Ever Previously Lead?	Service Line Installation Date (System Portion)	Service Line Size (inches) (System Portion)	Basis of Material Classification (System Portion)	Was the Service Line Material Field Verified? (System Portion)	Describe the Field Verification Method (System Portion)	Enter the Date of Field Verification (System Portion)	Notes (System Portion)	Customer-Owned Portion Service Line Material Classification*	Service Line Installation Date (Customer Portion)	Service Line Size (inches) (Customer Portion)	Basis of Material Classification (Customer Portion)	Was the Service Line Material Field Verified? (Customer Portion)	Describe the Field Verification Method (Customer Portion)	Enter the Date of Field Verification (Customer Portion)	Notes (Customer Portion)	Entire Service Line Material Classification (by Water System)
2																							
3	1001	123 example st. cityville NM, 87555				Non-Lead - Plastic		2001							Non-Lead - Plastic	2202							Non-Lead
4	1002	124 example st. cityville NM, 87555				Galvanized		1989							Galvanized	1990							Non-Lead
5	1003	125 example st. cityville NM, 87555				Non-Lead - Plastic		1994							Non-Lead - Plastic	1995							Non-Lead
6	1004	126 example st. cityville NM, 87555				Non-Lead - Plastic		2002							Non-Lead - Plastic	2002							Non-Lead
7	1005	127 example st. cityville NM, 87555				Non-Lead - Copper		1974							Non-Lead - Copper	1975							Non-Lead
8	1006	128 example st. cityville NM, 87555				Non-Lead - Copper		1981							Non-Lead - Copper	1982							Non-Lead
9	1007	129 example st. cityville NM, 87555				Galvanized		1988							Galvanized	1989							Non-Lead
10	1008	130 example st. cityville NM, 87555				Non-Lead - Plastic		1994							Non-Lead - Plastic	1995							Non-Lead
11	1009	131 example st. cityville NM, 87555				Non-Lead - Plastic		1995							Non-Lead - Plastic	1996							Non-Lead
12	1010	132 example st. cityville NM, 87555				Non-Lead - Plastic		1995							Non-Lead - Plastic	1996							Non-Lead
13	1011	133 example st. cityville NM, 87555				Non-Lead - Copper		1980							Non-Lead - Copper	1981							Non-Lead
14	1012	134 example st. cityville NM, 87555				Non-Lead - Plastic		1997							Non-Lead - Plastic	1981							Non-Lead
15	1013	135 example st. cityville NM, 87555				Non-Lead - Plastic		2002							Non-Lead - Plastic	1998							Non-Lead
16	1014	136 example st. cityville NM, 87555				Galvanized		1985							Galvanized	1986							Non-Lead
17	1015	137 example st. cityville NM, 87555				Non-Lead - Plastic		1991							Non-Lead - Plastic	1992							Non-Lead
18	1016	138 example st. cityville NM, 87555				Non-Lead - Plastic		1997							Non-Lead - Plastic	1998							Non-Lead
19	1017	139 example st. cityville NM, 87555				Galvanized		1990							Galvanized	1998							Non-Lead
20	1018	140 example st. cityville NM, 87555				Galvanized		1977							Galvanized	1978							Non-Lead
21	1019	141 example st. cityville NM, 87555				Non-Lead - Plastic		2000							Non-Lead - Plastic	2000							Non-Lead
22	1020	142 example st. cityville NM, 87555				Non-Lead - Plastic		2001							Non-Lead - Plastic	2002							Non-Lead
23	1021	143 example st. cityville NM, 87555				Non-Lead - Copper		2000							Non-Lead - Copper	2001							Non-Lead
24	1022	144 example st. cityville NM, 87555				Non-Lead - Copper		1985							Non-Lead - Copper	1986							Non-Lead
25	1023	145 example st. cityville NM, 87555				Non-Lead - Plastic		1986							Non-Lead - Plastic	1987							Non-Lead
26	1024	146 example st. cityville NM, 87555				Non-Lead - Copper		1981							Non-Lead - Copper	1982							Non-Lead
27	1025	147 example st. cityville NM, 87555				Lead		1960							Lead	1960							Lead



Lead Service line gets added to replacement plan



What is due November 01, 2027

Validation Pool

	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U	V	W
	Location Information					System-Owned Portion									Customer-Owned Portion								Entire Service Line
1	Unique Service Line ID*	Street Address*	Other Location Identifier	Sensitive Population? (Yes/No)	Disadvantaged Neighborhood? (Yes/No)	System-Owned Portion Service Line Material Classification*	If Non-Lead, Was Material Ever Previously Lead?	Service Line Installation Date (System Portion)	Service Line Size (inches) (System Portion)	Basis of Material Classification (System Portion)	Was the Service Line Material Field Verified? (System Portion)	Describe the Field Verification Method (System Portion)	Enter the Date of Field Verification (System Portion)	Notes (System Portion)	Customer-Owned Portion Service Line Material Classification*	Service Line Installation Date (Customer Portion)	Service Line Size (inches) (Customer Portion)	Basis of Material Classification (Customer Portion)	Was the Service Line Material Field Verified? (Customer Portion)	Describe the Field Verification Method (Customer Portion)	Enter the Date of Field Verification (Customer Portion)	Notes (Customer Portion)	Entire Service Line Material Classification (by Water System)
2	1001	123 example st. cityville NM, 87555				Non-Lead - Plastic		2001							Non-Lead - Plastic	2202							Non-Lead
3	1002	124 example st. cityville NM, 87555				Galvanized		1989							Galvanized	1990							Non-Lead
4	1003	125 example st. cityville NM, 87555				Non-Lead - Plastic		1994							Non-Lead - Plastic	1995							Non-Lead
5	1004	126 example st. cityville NM, 87555				Non-Lead - Plastic		2002							Non-Lead - Plastic	2002							Non-Lead
6	1005	127 example st. cityville NM, 87555				Non-Lead - Copper		1974							Non-Lead - Copper	1975							Non-Lead
7	1006	128 example st. cityville NM, 87555				Non-Lead - Copper		1981							Non-Lead - Copper	1982							Non-Lead
8	1007	129 example st. cityville NM, 87555				Galvanized		1988							Galvanized	1989							Non-Lead
9	1008	130 example st. cityville NM, 87555				Non-Lead - Plastic		1994							Non-Lead - Plastic	1995							Non-Lead
10	1009	131 example st. cityville NM, 87555				Non-Lead - Plastic		1995							Non-Lead - Plastic	1996							Non-Lead
11	1010	132 example st. cityville NM, 87555				Non-Lead - Plastic		1995							Non-Lead - Plastic	1996							Non-Lead
12	1011	133 example st. cityville NM, 87555				Non-Lead - Copper		1980							Non-Lead - Copper	1981							Non-Lead
13	1012	134 example st. cityville NM, 87555				Non-Lead - Plastic		1997							Non-Lead - Plastic	1981							Non-Lead
14	1013	135 example st. cityville NM, 87555				Non-Lead - Plastic		2002							Non-Lead - Plastic	1998							Non-Lead
15	1014	136 example st. cityville NM, 87555				Galvanized		1985							Galvanized	1986							Non-Lead
16	1015	137 example st. cityville NM, 87555				Non-Lead - Plastic		1991							Non-Lead - Plastic	1992							Non-Lead
17	1016	138 example st. cityville NM, 87555				Non-Lead - Plastic		1997							Non-Lead - Plastic	1998							Non-Lead
18	1017	139 example st. cityville NM, 87555				Galvanized		1990							Galvanized	1998							Non-Lead
19	1018	140 example st. cityville NM, 87555				Galvanized		1977							Galvanized	1978							Non-Lead
20	1019	141 example st. cityville NM, 87555				Non-Lead - Plastic		2000							Non-Lead - Plastic	2000							Non-Lead
21	1020	142 example st. cityville NM, 87555				Non-Lead - Plastic		2001							Non-Lead - Plastic	2002							Non-Lead
22	1021	143 example st. cityville NM, 87555				Non-Lead - Copper		2000							Non-Lead - Copper	2001							Non-Lead
23	1022	144 example st. cityville NM, 87555				Non-Lead - Copper		1985							Non-Lead - Copper	1986							Non-Lead
24	1023	145 example st. cityville NM, 87555				Non-Lead - Plastic		1986							Non-Lead - Plastic	1987							Non-Lead
25	1024	146 example st. cityville NM, 87555				Non-Lead - Copper		1981							Non-Lead - Copper	1982							Non-Lead



What is due November 01, 2027

Validation Pool

	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U	V	W
1	Location Information					System-Owned Portion									Customer-Owned Portion							Entire Service Line	
	Unique Service Line ID*	Street Address*	Other Location Identifier	Sensitive Population? (Yes/No)	Disadvantaged Neighborhood? (Yes/No)	System-Owned Portion Service Line Material Classification*	If Non-Lead, Was Material Ever Previously Lead?	Service Line Installation Date (System Portion)	Service Line Size (inches) (System Portion)	Basis of Material Classification (System Portion)	Was the Service Line Material Field Verified? (System Portion)	Describe the Field Verification Method (System Portion)	Enter the Date of Field Verification (System Portion)	Notes (System Portion)	Customer-Owned Portion Service Line Material Classification*	Service Line Installation Date (Customer Portion)	Service Line Size (inches) (Customer Portion)	Basis of Material Classification (Customer Portion)	Was the Service Line Material Field Verified? (Customer Portion)	Describe the Field Verification Method (Customer Portion)	Enter the Date of Field Verification (Customer Portion)	Notes (Customer Portion)	Entire Service Line Material Classification (by Water System)
2																							
3	1001	123 example st. cityville NM, 87555				Non-Lead - Plastic		2001							Non-Lead - Plastic	2202							Non-Lead
4	1002	124 example st. cityville NM, 87555				Galvanized		1989							Galvanized	1990							Non-Lead
5	1003	125 example st. cityville NM, 87555				Non-Lead - Plastic		1994							Non-Lead - Plastic	1995							Non-Lead
6	1004	126 example st. cityville NM, 87555				Non-Lead - Plastic		2002							Non-Lead - Plastic	2002							Non-Lead
7	1005	127 example st. cityville NM, 87555				Non-Lead - Copper		1974							Non-Lead - Copper	1975							Non-Lead
8	1006	128 example st. cityville NM, 87555				Non-Lead - Copper		1981							Non-Lead - Copper	1982							Non-Lead
9	1007	129 example st. cityville NM, 87555				Galvanized		1988							Galvanized	1989							Non-Lead
10	1008	130 example st. cityville NM, 87555				Non-Lead - Plastic		1994							Non-Lead - Plastic	1995							Non-Lead
11	1009	131 example st. cityville NM, 87555				Non-Lead - Plastic		1995							Non-Lead - Plastic	1996							Non-Lead
12	1010	132 example st. cityville NM, 87555				Non-Lead - Plastic		1995							Non-Lead - Plastic	1996							Non-Lead
13	1011	133 example st. cityville NM, 87555				Non-Lead - Copper		1980							Non-Lead - Copper	1981							Non-Lead
14	1012	134 example st. cityville NM, 87555				Non-Lead - Plastic		1997							Non-Lead - Plastic	1981							Non-Lead
15	1013	135 example st. cityville NM, 87555				Non-Lead - Plastic		2002							Non-Lead - Plastic	1998							Non-Lead
16	1014	136 example st. cityville NM, 87555				Galvanized		1985							Galvanized	1986							Non-Lead
17	1015	137 example st. cityville NM, 87555				Non-Lead - Plastic		1991							Non-Lead - Plastic	1992							Non-Lead
18	1016	138 example st. cityville NM, 87555				Non-Lead - Plastic		1997							Non-Lead - Plastic	1998							Non-Lead
19	1017	139 example st. cityville NM, 87555				Galvanized		1990							Galvanized	1998							Non-Lead
20	1018	140 example st. cityville NM, 87555				Galvanized		1977							Galvanized	1978							Non-Lead
21	1019	141 example st. cityville NM, 87555				Non-Lead - Plastic		2000							Non-Lead - Plastic	2000							Non-Lead
22	1020	142 example st. cityville NM, 87555				Non-Lead - Plastic		2001							Non-Lead - Plastic	2002							Non-Lead
23	1021	143 example st. cityville NM, 87555				Non-Lead - Copper		2000							Non-Lead - Copper	2001							Non-Lead
24	1022	144 example st. cityville NM, 87555				Non-Lead - Copper		1985							Non-Lead - Copper	1986							Non-Lead
25	1023	145 example st. cityville NM, 87555				Non-Lead - Plastic		1986							Non-Lead - Plastic	1987							Non-Lead
26	1024	146 example st. cityville NM, 87555				Non-Lead - Copper		1981							Non-Lead - Copper	1982							Non-Lead

Service lines with records of installation after June 19, 1988 should be excluded.



What is due November 01, 2027

Validation Pool

	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U	V	W
1	Location Information					System-Owned Portion									Customer-Owned Portion							Entire Service Line	
	Unique Service Line ID*	Street Address*	Other Location Identifier	Sensitive Population? (Yes/No)	Disadvantaged Neighborhood? (Yes/No)	System-Owned Portion Service Line Material Classification*	If Non-Lead, Was Material Ever Previously Lead?	Service Line Installation Date (System Portion)	Service Line Size (inches) (System Portion)	Basis of Material Classification (System Portion)	Was the Service Line Material Verified? (System Portion)	Describe the Field Verification Method (System Portion)	Enter the Date of Field Verification (System Portion)	Notes (System Portion)	Customer-Owned Portion Service Line Material Classification*	Service Line Installation Date (Customer Portion)	Service Line Size (inches) (Customer Portion)	Basis of Material Classification (Customer Portion)	Was the Service Line Material Verified? (Customer Portion)	Describe the Field Verification Method (Customer Portion)	Enter the Date of Field Verification (Customer Portion)	Notes (Customer Portion)	Entire Service Line Material Classification (by Water System)
2																							
7	1005	127 example st. cityville NM, 87555				Non-Lead - Copper		1974							Non-Lead - Copper	1975							Non-Lead
8	1006	128 example st. cityville NM, 87555				Non-Lead - Copper		1981							Non-Lead - Copper	1982							Non-Lead
13	1011	133 example st. cityville NM, 87555				Non-Lead - Copper		1980							Non-Lead - Copper	1981							Non-Lead
16	1014	136 example st. cityville NM, 87555				Galvanized		1985							Galvanized	1986							Non-Lead
20	1018	140 example st. cityville NM, 87555				Galvanized		1977							Galvanized	1978							Non-Lead
24	1022	144 example st. cityville NM, 87555				Non-Lead - Copper		1985							Non-Lead - Copper	1986							Non-Lead
25	1023	145 example st. cityville NM, 87555				Non-Lead - Plastic		1986							Non-Lead - Plastic	1987							Non-Lead
26	1024	146 example st. cityville NM, 87555				Non-Lead - Copper		1981							Non-Lead - Copper	1982							Non-Lead

This Validation Pool will consist of 8 service lines.



What is due November 01, 2027

□ Validation Pool

From the pool, a number of lines will need to have documentation of date and method the service line was validated.

Size of validation pool	Number of validations required
<1,500	20 percent of validation pool.
1,500 to 2,000	322.
2,001 to 3,000	341.
3,001 to 4,000	351.
4,001 to 6,000	361.
6,001 to 10,000	371.
10,001 to 50,000	381.
>50,000	384.



What is due November 01, 2027

Validation Pool

	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U	V	W
1	Location Information					System-Owned Portion									Customer-Owned Portion								Entire Service Line
	Unique Service Line ID*	Street Address*	Other Location Identifier	Sensitive Population? (Yes/No)	Disadvantaged Neighborhood? (Yes/No)	System-Owned Portion Service Line Material Classification*	If Non-Lead, Was Material Ever Previously Lead?	Service Line Installation Date (System Portion)	Service Line Size (inches) (System Portion)	Basis of Material Classification (System Portion)	Was the Service Line Material Verified? (System Portion)	Describe the Field Verification Method (System Portion)	Enter the Date of Field Verification (System Portion)	Notes (System Portion)	Customer-Owned Portion Service Line Material Classification*	Service Line Installation Date (Customer Portion)	Service Line Size (inches) (Customer Portion)	Basis of Material Classification (Customer Portion)	Was the Service Line Material Verified? (Customer Portion)	Describe the Field Verification Method (Customer Portion)	Enter the Date of Field Verification (Customer Portion)	Notes (Customer Portion)	Entire Service Line Material Classification (by Water System)
2																							
7	1005	127 example st. cityville NM, 87555				Non-Lead - Copper		1974							Non-Lead - Copper	1975							Non-Lead
8	1006	128 example st. cityville NM, 87555				Non-Lead - Copper		1981							Non-Lead - Copper	1982							Non-Lead
13	1011	133 example st. cityville NM, 87555				Non-Lead - Copper		1980							Non-Lead - Copper	1981							Non-Lead
16	1014	136 example st. cityville NM, 87555				Galvanized		1985							Galvanized	1986							Non-Lead
20	1018	140 example st. cityville NM, 87555				Galvanized		1977							Galvanized	1978							Non-Lead
24	1022	144 example st. cityville NM, 87555				Non-Lead - Copper		1985							Non-Lead - Copper	1986							Non-Lead
25	1023	145 example st. cityville NM, 87555				Non-Lead - Plastic		1986							Non-Lead - Plastic	1987							Non-Lead
26	1024	146 example st. cityville NM, 87555				Non-Lead - Copper		1981							Non-Lead - Copper	1982							Non-Lead

This Validation Pool will consist of 8 service lines. Based on the chart, 2 service lines will need to be validated.



What is due November 01, 2027

□ Validation Pool – What needs to be turned in?

Itemized list of service lines installed before June 19th, 1988 known to be lead free with a pre-designated number of randomly selected locations to be validated and a description of the pool.

Unique Service Line ID*	Street Address*	Other Location Identifier	Sensitive Population? (Yes/No)	Disadvantaged Neighborhood? (Yes/No)	System-Owned Portion Service Line Material Classification*	Service Line Installation Date (System Portion)	Customer-Owned Portion Service Line Material Classification*	Service Line Installation Date (Customer Portion)	Entire Service Line Material Classification (by Water System)
1005	127 example st. cityville NM, 87555				Non-Lead - Copper	1974	Non-Lead - Copper	1975	Non-Lead
1006	128 example st. cityville NM, 87555				Non-Lead - Copper	1981	Non-Lead - Copper	1982	Non-Lead
1011	133 example st. cityville NM, 87555				Non-Lead - Copper	1980	Non-Lead - Copper	1981	Non-Lead
1014	136 example st. cityville NM, 87555				Galvanized	1985	Galvanized	1986	Non-Lead
1018	140 example st. cityville NM, 87555				Galvanized	1977	Galvanized	1978	Non-Lead
1022	144 example st. cityville NM, 87555				Non-Lead - Copper	1985	Non-Lead - Copper	1986	Non-Lead
1023	145 example st. cityville NM, 87555				Non-Lead - Plastic	1986	Non-Lead - Plastic	1987	Non-Lead
1024	146 example st. cityville NM, 87555				Non-Lead - Copper	1981	Non-Lead - Copper	1982	Non-Lead

The system contains 25 service lines. 8 service lines met the criteria for the validation pool. Since the system's Validation pool is >1500, only 2 service lines need to be validated. Based on a random number generator, 128 example St. and 146 Example St. will be validated through excavation.



Future Deadlines

57

How do I validate a service lines material?

Visual inspection of the pipe exterior at a minimum of two points (at least one point on the customer's side, and at least one point on the system's side when the service line is shared.)

Excavation (pot holing)

CCTV

visual inspection in the meter pit or stop box

“no dig” probing.



Future Deadlines

58

When do I need the validation?

The actual validation must be accomplished by December 31st 2033

How

Visual inspection of the pipe exterior at a minimum of two points (at least one point on the customer's side, and at least one point on the system's side when the service line is shared.)

Excavation (pot holing)

visual inspection in the meter pit or stop box

CCTV

"no dig" probing.



Future Deadlines

A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U	V	W
Unique Service Line ID*	Street Address*	Other Location Identifier	Sensitive Population? (Yes/No)	Disadvantaged Neighborhood? (Yes/No)	System-Owned Portion Service Line Material Classification*	If Non-Lead, Was Material Ever Previously Lead?	Service Line Installation Date (System Portion)	Service Line Size (inches) (System Portion)	Basis of Material Classification (System Portion)	Was the Service Line Material Field Verified? (System Portion)	Describe the Field Verification Method (System Portion)	Enter the Date of Field Verification (System Portion)	Notes (System Portion)	Customer-Owned Portion Service Line Material Classification*	Service Line Installation Date (Customer Portion)	Service Line Size (inches) (Customer Portion)	Basis of Material Classification (Customer Portion)	Was the Service Line Material Field Verified? (Customer Portion)	Describe the Field Verification Method (Customer Portion)	Enter the Date of Field Verification (Customer Portion)	Notes (Customer Portion)	Entire Service Line Material Classification (by Water System)
1001	123 example st. cityville NM, 87555				Non-Lead - Plastic		2001							Non-Lead - Plastic	2202							Non-Lead
1002	124 example st. cityville NM, 87555				Galvanized		1989							Galvanized	1990							Non-Lead
1003	125 example st. cityville NM, 87555				Non-Lead - Plastic		1994							Non-Lead - Plastic	1995							Non-Lead
1004	126 example st. cityville NM, 87555				Non-Lead - Plastic		2002							Non-Lead - Plastic	2002							Non-Lead
1005	127 example st. cityville NM, 87555				Non-Lead - Copper		1974							Non-Lead - Copper	1975							Non-Lead
1006	128 example st. cityville NM, 87555				Non-Lead - Copper		1981		Yes	Mechanical excavation	5/24/2026			Non-Lead - Copper	1982			Yes	Mechanical excavation	5/24/2026		Non-Lead
1007	129 example st. cityville NM, 87555				Galvanized		1988							Galvanized	1989							Non-Lead
1008	130 example st. cityville NM, 87555				Non-Lead - Plastic		1994							Non-Lead - Plastic	1995							Non-Lead
1009	131 example st. cityville NM, 87555				Non-Lead - Plastic		1995							Non-Lead - Plastic	1996							Non-Lead
1010	132 example st. cityville NM, 87555				Non-Lead - Plastic		1995							Non-Lead - Plastic	1996							Non-Lead
1011	133 example st. cityville NM, 87555				Non-Lead - Copper		1980							Non-Lead - Copper	1981							Non-Lead
1012	134 example st. cityville NM, 87555				Non-Lead - Plastic		1997							Non-Lead - Plastic	1981							Non-Lead
1013	135 example st. cityville NM, 87555				Non-Lead - Plastic		2002							Non-Lead - Plastic	1998							Non-Lead
1014	136 example st. cityville NM, 87555				Galvanized		1985							Galvanized	1986							Non-Lead
1015	137 example st. cityville NM, 87555				Non-Lead - Plastic		1991							Non-Lead - Plastic	1992							Non-Lead
1016	138 example st. cityville NM, 87555				Non-Lead - Plastic		1997							Non-Lead - Plastic	1998							Non-Lead
1017	139 example st. cityville NM, 87555				Galvanized		1990							Galvanized	1998							Non-Lead
1018	140 example st. cityville NM, 87555				Galvanized		1977							Galvanized	1978							Non-Lead
1019	141 example st. cityville NM, 87555				Non-Lead - Plastic		2000							Non-Lead - Plastic	2000							Non-Lead
1020	142 example st. cityville NM, 87555				Non-Lead - Plastic		2001							Non-Lead - Plastic	2002							Non-Lead
1021	143 example st. cityville NM, 87555				Non-Lead - Copper		2000							Non-Lead - Copper	2001							Non-Lead
1022	144 example st. cityville NM, 87555				Non-Lead - Copper		1985							Non-Lead - Copper	1986							Non-Lead
1023	145 example st. cityville NM, 87555				Non-Lead - Plastic		1986							Non-Lead - Plastic	1987							Non-Lead
1024	146 example st. cityville NM, 87555				Non-Lead - Copper		1981		Yes	Mechanical excavation	5/17/2026			Non-Lead - Copper	1982			Yes	Mechanical excavation	5/17/2026		Non-Lead
1025	147 example st. cityville NM, 87555				Lead		1960							Lead	1960							Lead



Future Deadlines

60

December 31st 2033

Validation of at least 20% of non-lead lines

Demonstrate that replacement plan/strategy is working and will be accomplishable by 2037.



Future Deadlines

61

November 2037

All service lines should be known to be lead free.



Contact Information

Thomas Shiparski

121 Tijeras Ave. NE

Albuquerque, NM 871012

thomas.shiparski@env.nm.gov

505-372-8166